


Room 1



Clearance height: 9.000 ft, Reflection factors: Ceiling 70.0%, Walls 50.0%, Floor 20.0%, Light loss factor: 0.90

Workplane


Surface	Result	Average (Target)	Min	Max	Mean/Min	Max/Min
1 Workplane 1	Perpendicular illuminance (adaptive) [fc] Height: 2.500 ft, Wall zone: 0.000 ft	61.83 (≥ 92.90)	36.71	74.21	1.68	2.02

#	Luminaire	Φ(Luminaire) [lm]	Power [W]	Luminous efficacy [lm/W]
4	4FT 2-LAMP STRIP LIGHT 22W-2640 LM / BULB X2 5000K 2 LED TUBES	5280	44.0	120.0
Total via all luminaires		21120	176.0	120.0

Lighting power density: 0.97 W/sq ft = 0.15 W/sq ft/10 fc (Floor area of room 182.25 sq ft)


The energy consumption quantities refer to the lights planned for the room without taking into account light scenes and their dimming levels.
Consumption: 400 kWh/a of maximum 600 kWh/a

Room 1



No.	X [ft]	Y [ft]	Mounting height [ft]
1	3.375	3.375	9.000
2	10.125	3.375	9.000
3	3.375	10.125	9.000
4	10.125	10.125	9.000

Workplane 1 / Perpendicular illuminance (adaptive)




Workplane 1: Perpendicular illuminance (adaptive) (Surface)

Light scene: Light scene 1

Average: 61.83 fc (Target: ≥ 92.90 fc), Min: 36.71 fc, Max: 74.21 fc, Mean/Min: 1.68, Max/Min: 2.02


Height: 2.500 ft, Wall zone: 0.000 ft

Isolines [fc]




Scale: 1 : 25

False colors [fc]



Scale: 1 : 25

Value grid [fc]



Scale: 1 : 25